

Use and maintenance instructions **INDUS**

Street lighting luminaire for installation on poles or brackets Ø60mm on top. TECHNICAL DETAILS: please refer to the product label



The EU declaration of conformity can be downloaded from our website www.marecoluce.it



Insulation Class II

IP66

Protection degree against dust ingress, solid particles, moisture



This luminaire holds a lighting source in "D" energy efficiency class.

other applications for which lighting standards allow a CRI <80.

CRI<80 This product is intended for use in outdoor applications, industrial applications and

Caution, risk of electrical shock. The lighting source of this luminaire must be replaced



This product must not be disposed as a normal household waste

WARNINGS:

THE SAFETY OF THIS PRODUCT IS GUARANTEED ONLY WITH THE RESPECT OF THE EXISTING RULES FOR THE ELECTRICAL SYSTEMS, AND WITH THE APPROPRIATE USE OF THESE

- INSTALLATION INSTRUCTIONS, THEREFORE IT IS NECESSARY TO KEEP THEM.

 THE IMPROPER USE OF THIS PRODUCT IS FORBIDDEN; ANY TAMPERING WITH THE PRODUCT OR MODIFICATION OF THE PRODUCT THAT IS NOT AUTHORIZED BY MARECO LUCE CAN CAUSE DAMAGE TO PEOPLE, ANIMALS OR THINGS, AND WILL VOID ANY WARRANTY OR LIABILITY.
- SWITCH OFF THE ELECTRICITY BEFORE CONDUCTING ANY KIND OF MAINTENANCE.
- THE PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH BEST PRACTICE.
- DAMAGED COMPONENTS MUST BE REPLACED WITH MARECO LUCE ORIGINAL SPARE PARTS BEFORE REUSING THE PRODUCT.

	Housing A	Housing B
The luminaire can be installed on poles of max height	8 mt	15 mt
Suitable for mounting	On pole and bracket	On pole and bracket
Luminaire weight	4,1 Kg	6,8 Kg
Maximum projected surface area subject to wind pressure	//	0,186 mq
Torque value (in Nm) to apply in tightening all bolts and screws securing the luminaire on its support	2,5 Nm	2,5 Nm

GENERAL MAINTENANCE RECOMMENDATIONS:

- CLEAN THE LUMINAIRE PERIODICALLY TO REMOVE POSSIBLE DIRT DEPOSITS THAT MAY DAMAGE IT OR ALTER THE PHOTOMETRICS PERFORMANCE.
- DO NOT USE HARSH DETERGENTS, ABRASIVE CLOTHES, HIGH- PRESSURE WASHERS, WATER AT A TEMPERATURE HIGHER THAN 60°C TO CLEAN THE LUMINAIRE.
- CHECK THE TIGHTNESS OF THE SCREWS SECURING THE LUMINAIRE TO ITS SUPPORT.
- CHECK THE INTEGRITY OF THE COMPONENTS AND REPLACE THEM IN CASE OF ANY DAMAGE BY USING ORIGINAL MARECO LUCE SPARE PARTS.

INSTALLATION INSTRUCTIONS:


by the Manufacturer only

1. Open the side clips (1) and remove the top of the base support (2).

2. Adjust the luminaire position according to the type of installation (see Pict.1 or Pict.2) by completely untightening the screws (3) securing the pole top adaptor (4) to the base support (2). Once you have you have set the angle the pole top adaptor (4), tighten the screws (3) strongly.

3. Insert the supply cable (5) through the cable gland (6), and connect it to the terminal of the disconnecting switch (7) by respecting the polarities and the luminaire's insulation class.

A CAUTION: use only a flexible double insulation sheath (type HAR or suitable for outdoor use). The outer cable diameter must be between 6 and 12mm and the thickness of the inner electrical wires must range between 1 and 2.5mmg.



SUPPLEMENTARY MAINTENANCE TO REPLACE THE WIRING TRAY:

The luminaire Indus is equipped with a replaceable gear tray thanks to a tool free fast hooking system

- 1. Unhook the closing clips (1) and remove the whole LED wired tray (9).
- 2. Unfasten the wiring tray (11) by rotating the relevant lock (12).
- 3. Disconnect the quick release connectors out of the driver.
- 4. Replace the wiring tray (11), by connecting the drivers's quick release wires and pay attention to respect the colours and cable polarity.
- **5.**Put back the lock **(12)** in the initial position in order to secure the wiring tray **(11)**.
- 6. Place the whole LED wired tray (9), over the side hooks (10) of the base support (2), and close the side clips (1).

