47032 bertinoro (FC) Italia
via s.croce, 121 (z.i.)
tel. +39 0543 4687
fax +39 0543 449051
info@marecoluce.it
www.marecoluce.it

This document is exclusive MARECO LUCE s.r.l., is strictly prohibited disclosure or reproduction, even partial, as well the use of without written consent of MARECO LUCE s.r.l..The company reserves the right to change models, dimensions and materials at any time without notice.

PRODUCT DATA SHEET
Piave Ø76/60
Code : 1407200S



PRODUCT FAMILY
- Cilyndrical Ø76/60mm pole for ground or plinth/floor fixing, suitable for luminaire installation on top

MATERIAL CHARACTERISTICS
- Cylindrical pole conforming to DIN norm, made of hot-dip galvanised steel 75m UNI EN 1461 and painting
- Polyester powder coating with a pretreatment (Phosphochromating method) to ensure high protection against weathering
- A2 stainless steel screws

BURIED POLE - SYSTEM A
- Cylindrical pole Ø76/60x4100/5100mm conforming to DIN norm, for ground fixing made of hot-dip galvanised steel 75m UNI EN 1461
- Total ground height 3600/4500mm
- Suggested plinth 600x600x700mm

FLANGED POLE - SYSTEM B
- Cylindrical pole Ø76/60x4100/5100mm conforming to DIN norm, for plinth/floor fixing complete with flange made of hot-dip galvanised steel 75m UNI EN 1461
- Total ground height 4100/5100mm
- 250x250mm flange, 10mm thick made of hot-dip galvanised steel 75m UNI EN 1461
- Suggested plinth 600x600x700mm

COMPULSORY ACCESSORY SYSTEM B - COD.40000002
- Counter flange 250x250x3mm and anchor bolts kit M16x500mm (n°4) with n°8 nut and n°8 washers made of hot-dip galvanised steel 75m UNI EN 1461

COLOUR
- Anthracite RAL 7016 textured

INSTALLATION AND ORDINARY MAINTENANCE CHARACTERISTICS
- Class II hole and terminal block, 4-poles, 3 way with IN/OUT power supply (6mmq) and connecting to the lamp with fuse holder for 8.5x31.5mm fuses
- Closing door made of painted aluminium
- Hole for cable passage (buried part of pole System A)
- Hole on flange for cable passage into pole and hole on pole for earthing cable (System B)
- M10 earthing bolt

Rev. 3 - 09/03/20

Details
• IP